

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

South Hunterdon Regional High School Has Levels of Perfluorononanoic (PFNA) Above Drinking Water Standards

Our water system recently violated a New Jersey drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

We routinely monitor for the presence of drinking water contaminants. On 9/23/2019, we received notice that the sample collected on 08/02/2019 showed that our system exceeds the standard, or maximum contaminant level (MCL), for PFNA. The New Jersey standard for PFNA is 0.013 µg/L. The average level of PFNA over the last year has been 0.033 µg/L.

What should I do?

- There is nothing you need to do. **You do not need to boil your water** or take other corrective actions. However, if you have specific health concerns, consult your doctor.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water.

What does this mean?

This is not an emergency. If it had been, you would have been notified within 24 hours. However, some people who drink water containing PFNA in excess of the MCL over many years could experience problems with their liver; kidney; immune system; or, in males, reproductive system. For females, drinking water containing PFNA in excess of the MCL over many years may cause developmental delays in a fetus and or infant.

For more information refer to [https://www.state.nj.us/dep/wms/bears/docs/2019-4-15-FAQs_PFOS-PFOA-websites-OLA%204-24-19SDM-\(003\).pdf](https://www.state.nj.us/dep/wms/bears/docs/2019-4-15-FAQs_PFOS-PFOA-websites-OLA%204-24-19SDM-(003).pdf)

What is being done?

We have chosen a vendor and the appropriate treatment equipment will be installed within the next 6 weeks for the newly regulated contaminant.

For more information, please contact Kerry Sevilis at (609)397-2060 ext. 1264 or 301 Mt. Airy Harbourton Rd, Lambertville, NJ 08530.

**Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail. **

This notice is being sent to you by South Hunterdon Regional High School
State Water System ID#: NJ1026302.

Date distributed: 11/8/2019